



NOTES:
 1. Concrete to test 4500 psi min.
 2. All conc. to be properly cured using a curing compound or other approved acceptable method.
 3. A half inch expansion joint of a non-extrudable bitumastic material shall be placed as shown.

REVISED 3-3-20 CURB TRANSITION, HANDICAP RAMP, STABILIZING

Lantelme, Kurens & Associates, P.C. Engineers & Land Surveyors
 101 West Street, P.O. Box 486, Hillsdale, New Jersey 07642 (201) 666-2450

SCALE: 1"=20'
 DATE: MARCH 4, 2019
 PARTY: GB/DR
 PREPARED BY: CJL
 DRAWN BY: SPM
 LOT No.: 18.01-18.04 (T.M.)
 BLOCK No.: 501 (F.M.)
 FILE No.: 411CLINTON-ROAD

ROADWAY REALIGNMENT
Lots 18.01 - 18.04, Block 501
Borough of Northvale, Bergen County, N.J.
 MAP SOURCE: TAX ASSESSMENT MAP OF THE BOROUGH OF NORTHVALE, BERGEN COUNTY, NEW JERSEY.

Christopher Lantelme
 Christopher Lantelme
 P.E. & L.S. 39580